


Nr. cad. 257300

Oedul Gilnic Anunada - Aced in 47021.5.12.2024
2089/2024 2024



Nr. cad. 217995

Judetul : DOLO
UAT: CRAIOVA
ALEEA 1 SIMNIC

Nr. cad. 257300

Nr. cad. 224157
204028 204028-11
204028

Conductor 0.4kV protectat circuit 9
T2X 95+3x120 mmp
Lungime 420m

SC 10005 ex
Nr. 5
DI 165551

Nr. cad. 259316

Nr. cad. 259279

Nr. cad. 254929

Nr. cad. 259321

Nr. cad. 259306

Nr. cad. 257277

Nr. Pct.	Coordonate puncte stereo 70	
	X [m]	Y [m]
PTA 169 Craiova (PTA-10-166)	404763.134	317022.085
Firida Stradala E 2-4 protectata	404764.572	317026.111
Stalp SC 10005 existent nr.2	404764.712	317002.663
Stalp SC 10005 protectat nr.31	404761.763	316986.757
Stalp SC 15005 existent nr.3	404757.311	316950.275
Stalp SC 10002 protectat nr.4	404750.587	316901.761
Stalp SC 10005 existent nr.5	404745.332	316865.398
Stalp SE 4 existent nr.6	404739.641	316828.243
Stalp SC 10002 protectat nr.7	404733.057	316792.066
Stalp SC 10002 protectat nr.8	404727.571	316754.919
Stalp SC 10005 existent nr.9	404721.860	316719.771

Verificator de proiecte in domeniul instalatiilor electrice tehnologie
Adeverinta nr 20192023981024.2019

Lucia CRISTIAN - CONSTANTIN
CNP 1720828284384



LEGENDA

- LEA 0,4 kV existenta
- LEA 0,4 kV proiectata
- Cutie Distribuie pre-existenta
- Firida Stradala HDGS tip E protectata
- Stalp beton tip SE existent
- Stalp beton tip SC existent
- Stalp beton tip SC protectat
- Descarcator tip pr
- Priza pamant 10 ohm pr.
- Instalati Gaze naturale
- Instalati apa cald
- Instalati telecomunicatii

Verificator Exp.	Nume	Semnatura	Cerinta	Raport experienta nr Data
Beneficiar:	SC DISTRIBUTIE ENERGIE OLTEANSA			
Nr desen:	Al-255190 2a-PE-Ep403	Revizie:	0	
Ing. Mihail Victor	Forma	Forma	0	
Ing. Valo Emil	Forma	Forma	0	
Proiectant	Ing. Valo Emil			
Aprobat				