

The drawing consists of a plan view at the top and a section view at the bottom.

Plan View: Shows a sewerage line running parallel to a road labeled "Strada Bogdan Petriceicu Hasdeu (fosta str. Comului)". The sewerage line is labeled "Conducta proiectata GN MP PE100 SDR11 Dn90mm, L=238.0 m". Various manholes are marked with numbers (51, 53, 55, 57, 59, 61, 63, 65, 67, 69C, 69, 71, 73, 75, 77, 79, 81, 83A, 83). Distances between manholes are indicated: 0.7m, 1.6m, 3.2m, 1.6m, 0.5m, 3.6m, 1.1m, 2.8m. A north arrow is present in the top left.

Section View (SECTIUNEA: 1 - 1): Shows a cross-section of the road and sewerage system. The road width is 6.5m, with 1.7m sidewalks on each side. The sewerage line is shown at a depth of -0.90m. It includes an existing sewerage line ("Conducta canalizare existenta") and a new project sewerage line ("Conducta proiectata GN MP PE100 SDR11 Dn90mm"). A note indicates "Conducta existenta GN RP OL Ø3" ce se va dezafecta". The section is bounded by property lines ("limita de proprietate").


Administrative Stamps:

- Top right: "JUDETUL DOLJ PRIMĂRIA MUNICIPIULUI CRAIOVA VIZAT SPRE NESCHIMBARE NR. 7 din 20.12.2014. Anexa la autorizatia de construire Nr. 918 din 20.12.2014. Arhitect sef. [Signature]"
- Bottom right: Circular stamp of "ING. LUCIAN-MARIUS ANRE NR.V131100057 A.B.C.D.E.F. INGINIER VERIFICATOR PROIECTE"

Table: A small table is located in the top right corner, likely a schedule of materials or costs, with columns for item number, description, and quantity.

[illegible]

Strada Bogdan Petriceicu Hasdeu (fosta
str.Cornului)



LEGENDA

Zona de estudio	
Chico	
Acuña (estación)	
Acuña (estación)	
Calle vecinales	
Plano 1:1000	
Calles vecinales	
Troncales	
Calle de Barrio pto.	
Canal	
Calle Cito	
Calle de Barrio	
Acuña Cito	
Higüey	
Reserva provincial	
Higüey municipal	
Troncal pto.	

	Conducta gaze naturale MP /PE existenta
	Conducta gaze naturale RP /PE existenta
	Conducta gaze naturale RP /OL existenta
	Conducta gaze naturale MP proiectata PE 100 SDR11
	Conducta gaze naturale RP existenta ce se va dezafecta
	Bransament gaze naturale MP proiectat PE 100 SDR11
	Bransament gaze naturale RP existent ce se va dezafecta
	Conducta canalizare menajera existenta
	Linie electrica aeriana
	Punct de cuplare
	Cap terminal
	Vana otel in camin-beton existenta ce se va dezafecta
	Vana PE in camin tip clopot existenta ce se va dezafecta
	Tub protectie
	Pat de caramizi 1.0mx0.4m
	Sondaj 1.0x3.0m
	Post de reglare-masurare proiectate
	Post de reglare-masurare ce se va dezafecta
	Post de reglare-masurare ce se pastreaza
	Rasufloatoare GN carosabila

Aviz Apa Oltenia SA - Fisa tehnica emisa in 01.03.2024 -
Se vor convoca reprezentantii Companiei Apa Oltenia SA la predarea
amplasamentului inainte de inceperea lucrarilor pentru identificarea conductelor in
vederea protejarii acestora si pentru asistenta tehnica pe durata lucrarii.
Avez E-Distributie Oltenia nr. 060060996346/22.02.2024 -
In zona exista retea electrica de distributie de medie/ joasa tensiune monofazata si
trifazata.
Sapaturile in zona traseelor de cabluri, fundatii de stalpi se vor face numai
manual, cu asistenta tehnica din partea Centrului Operational Exploatare CE
MT JT Craiova Municipal al Distributie Energie Oltenia SA, telefon 0251408006

CONSTANTINIU MARIA
INSTALATOR AUTORIZAT - DE NATURALE
TIP PGIU LEGITIMATIA NR 101220116
TIP PGD LEGITIMATIA NR 10520128
PERIOADA DE VALABILITATE 12.05.2027

Schema de racordare p

G2	G3
----	----